

Declaration of Conformity

Henry Technologies hereby declare that the Pressure Equipment listed below has been designed, manufactured and tested in accordance with the requirements of the Pressure Equipment Regulations 1999 (European Directive 97/23/EC)

Description of Pressure Equipment: Safety Relief Valves


Conformity and Assessment Procedure followed:
Product Category : Cat IV
Modules : B + D

Model no.	Orifice size	Type Certificate no.	Fluid Group
526E-CE	0.25"	18730/B/2	2
5230A-CE	0.25"	18730/B/2	2
5231A-CE	0.25"	18730/B/2	2
5231B-CE	0.25"	18730/B/2	2

Model no.	Orifice size	Type Certificate no.	Fluid Group
5240-CE	0.375"	18730/B/3 Rev A	2
5242-CE	0.375"	18730/B/3 Rev A	2
5340-CE	0.375"	18730/B/3 Rev A	1 & 2
5342-CE	0.375"	18730/B/3 Rev A	1 & 2
5232A-CE	0.375"	18730/B/3 Rev A	2

Model no.	Orifice size	Type Certificate no.	Fluid Group
5244-CE	0.500"	18730/B/4	2
5344-CE	0.500"	18730/B/4	1 & 2
5344A-CE	0.500"	18730/B/4	1 & 2

Model no.	Orifice size	Type Certificate no.	Fluid Group
5345-CE	0.703"	18730/B/5	1 & 2
5246-CE	0.703"	18730/B/5	2
5346-CE	0.703"	18730/B/5	1 & 2



Classified for	Fluid Group 2	Fluid Group 1
Maximum Op. Temp	+ 107° C	+ 135°C
Minimum Op. Temp	- 40° C	- 29°C


The following transposed European standards and other technical specifications have been used: **ASME VIII Division 1**

Notified Body:

The Notified Body which inspected the manufacturers quality assurance system:

Plant Safety Ltd.
Parklands
Wilmslow Road
Didsbury
Manchester M20 2RE

Notified Body identification No. **0041**

Signed:  Quality Assurance Manager Date: 04/06/02
(Responsible Person - Name and actual Title)



Declaration of Conformity

Henry Technologies hereby declare that the Pressure Equipment listed below has been designed, manufactured and tested in accordance with the requirements of the Pressure Equipment Regulations 1999 (European Directive 97/23/EC)

Description of Pressure Equipment: Safety Relief Valves

Model no's.: 5233A-CE, 5233B-CE

Conformity and Assessment Procedure followed:

Product Category : Cat IV

Modules : B + D

Design Strength Test Pressure = 250 Bar (Type Approval)

Standard Pressure Settings in Bar				
25.0 Bar	31.0 Bar	35.0 Bar	40.0 Bar	46.0 Bar

Model no.	Orifice size	Type Certificate no.	Fluid Group
5233A-CE	0.25"	CE-0041-PED-B-HEN-001-07-GBR	2
5233B-CE	0.25"	CE-0041-PED-B-HEN-001-07-GBR	2

Classified for	Fluid Group 2
Maximum Op. Temp	+ 107° C
Minimum Op. Temp	- 40° C


The following transposed European standards and other technical specifications have been used: **ASME VIII Division 1**

Notified Body:

The Notified Body which inspected the manufacturers quality assurance system:

Bureau Veritas
 Parklands
 Wilmslow Road
 Didsbury
 Manchester M20 2RE

Notified Body identification No. **0041**

Signed:  Quality Assurance Manager Date 9.4.08
 (Responsible Person –Name and actual Title)

