



## Declaration of Conformity

Manufacturer: **CAREL Industries S.p.A.**  
Via dell'Industria, 11 35020 Brugine (PD) Italy

### 4-20mA pressure transducers

Code	Description
<b>SPKT00abCc</b>	RATIOMETRIC PRESSURE TRANSDUCER
<b>a</b>	<b>1</b> = Range 0÷10 Bar (0÷150 psia) <b>2</b> = Range -0.5÷7 Bar (-7÷100 psia) <b>3</b> = Range 0÷30 Bar (0÷435 psia) <b>4</b> = Range 0÷18,2 Bar (0-265 psia) <b>5</b> = Range 0÷5,2 Bar (0÷75 psia) <b>6</b> = Range 0÷1000 Pascal (0÷10 mBar) - differential pressure sensor <b>7</b> = Range 0÷2500 Pascal (0÷25 mBar) - differential pressure sensor <b>B</b> = Range 0÷45 Bar (0÷650 psia) <b>D</b> = Range 0÷150 Bar (0÷2175 psia) <b>G</b> = Range 0÷60 Bar (0÷870 psia)
<b>b</b>	<b>1</b> = Port fitting 1/4 SAE, 7/16" UNF female flare - Inox <b>5</b> = (differential pressure sensor) screw type elec. connections <b>8</b> = Port fitting 1/4 GAS male - Inox
<b>c</b>	<b>0</b> = Single packaging <b>1</b> = Multiple packaging

The manufacturer declares that all the above indicated products are in accordance with the EC Directive **2004/108/EC (EMC)**

Brugine, 08<sup>th</sup> May 2012

CAREL INDUSTRIES S.p.A.  
Technical Director  
Ing. *Umberto Bianchini*

