

TYPE APPROVAL CERTIFICATE

This is to certify:**That the Pressure Switch**

with type designation(s)

**KP 1, KP 1A, KP 2, KP 5, KP 5A, KP 6W, KP 6B,
KP 7W, KP 7B, KP 7S, KP 7BS, KP 7ABS,
KP 15, KP 15A, KP 17W, KP 17B, KP 17WB**

Issued to

**Danfoss A/S
Nordborg, Syddanmark, Denmark**

is found to comply with

DNV GL rules for classification – Ships, offshore units, and high speed and light craft**Application :****Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.****Location classes:**

Temperature	D
Humidity	B
Vibration	B
EMC	N/A
Enclosure	A

Issued at **Høvik** on **2018-06-12**This Certificate is valid until **2023-05-27**.DNV GL local station: **Fredericia**Approval Engineer: **Nils Jarem**for **DNV GL**

Digitally Signed By: Sneen, Ståle

Location: DNV GL Høvik, Norway

on behalf of

**Odd Magne Nesvåg
Head of Section**

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



Job Id: **262.1-028856-1**
Certificate No: **TAA00001VZ**

Product description

Pressure switch for compressors in refrigeration plants.

Media: fluorinated refrigerants, version ..A.. additional for ammonia

KP 1: for low pressure, - 0.2 to 7.5 bar

KP 2: for low pressure, - 0.2 to 5 bar

KP 5: for high pressure, 8 to 32 bar

KP 6: for high pressure, 8 to 42 bar

KP 7: for high pressure, double bellow, 8 to 32 bar

KP 15: dual pressure, for low and high pressure

KP 17: dual pressure, double bellow, for low and high pressure, 8 to 32 bar

KP..W.. = pressure control

KP..B.. = pressure control with external reset

KP..S.. = pressure control with internal reset

Output: 1 or 2 c/o - contacts

Rating: 16 A max, 400 V AC-1, AC-3, 10 A 400 V AC-15

Degree of protection: IP30, IP44, IP54

Place of manufacture

Danfoss Poland Sp. z o.o.

Ul. Chrzanowska 5

PL-05-825 Grodzisk Mazowiecki

Poland

Approval conditions

The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNV GL, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNV GL rules for classification of ships Pt.4 Ch.9 Control and monitoring systems.

Type Approval documentation

Drawing: 060-1731, 060-9101, 060-9102

Technical data: DKRCC.PD.CD0.A1.02/520H11562 dated 2016-09

Test Reports: CS-T, J. No 02-084 and J. No. 2002 222 of Danfoss

TÜV-Certificates: No. 01 202 931-B-10-0003 and No. 01 202 931-B-12-0021

Type approval renewal assessment report for 9148076 HH, DNV GL Gdynia 2018-04-26

Tests carried out


Applicable tests according to class guideline DNVGL-CG-0339, November 2016.

DIN 32733 / EN 12263

Marking of product

The products to be marked with:

- manufacturer name
- model name
- serial number
- power supply ratings



Job Id: **262.1-028856-1**
Certificate No: **TAA00001VZ**

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE