

Declaration of Conformity

Henry Technologies hereby declare that the Pressure Equipment listed below has been designed, manufactured and tested in accordance with the requirements of the Pressure Equipment Regulations 1999 (European Directive 97/23/EC)

Description of Pressure Equipment:

Description of Vessel / Assembly: Suction Line Accumulators

Models covered:

(Cat I) S-7057-CE, S-7057HE-CE, S-7057HP-CE, S-7061HE-CE

(Cat II) S-7063HE-CE, S-7065HE-CE, S-7615-CE, S-7621-CE, S-7625-CE,
 S-7721-CE, S-7721HE-CE, S-7722-CE, S-7725-CE, S-7725HE-CE, S-7726-CE

(Cat III) S-7731-CE, S-7731HE-CE, S-7741-CE, S-7741HE-CE

(Cat IV) S-7742-CE

Conformity and Assessment Procedure Followed

Category	Cat I	Cat II	Cat III	Cat IV
Module	A	D1	H	H1
Certificate		US.HTI.120.00	US.HTI.121.00	US.HTI.122.00
PV.	50 - 200	200 - 1000	700 - 1900	>2000

Classified for	Group 2 Gases
Design pressure	31/27.5 bar
Maximum Op. Temp	+ 130° C
Minimum Op. Temp	- 40° C

The following transposed European standards and other technical specifications have been used:

UL 207

ASME Section VIII div 1 ed 2001

Notified Body:

The Notified Body which inspected the manufacturers quality assurance system:



Hartford Steam Boiler International GmbH

P. O. Box 1520
 Frerener Str. 13
 D-49785 Lingen
 Germany

SULIAN PARKER

Notified Body identification No. **0871**

Signed: *[Signature]* Director of Engineering Date: 06.9.02
 (Responsible Person - Name and actual Title)