Information to identify the model(s) to which the information relates to:			If function includes heating: Indicate the heating season the			
Indoor unit model name			information relates to. Indicated values should relate to one			
Outdoor unit model name	SRC71ZF	R-S	heating season at a time. Include at least the	heating seas	son 'Average	·.
				N		
Function(indicate if present)	Yes		Average(mandatory) Warmer(if designated)	Yes		
cooling heating	Yes		Colder(if designated)	Yes No		
incating	163					
Item	symbol	value unit	Item	symbol	value	class
Design load			Seasonal efficiency and energy efficiency cla			
cooling	Pdesignc	7.10 kW	cooling	SEER	7.20	A++
heating / Average	Pdesignh	6.60 kW	heating / Average	SCOP/A	4.50	A+
heating / Warmer	Pdesignh	8.30 kW	heating / Warmer	SCOP/W	5.70	A+++
heating / Colder	Pdesignh	- kW	heating / Colder	SCOP/C	-	
Declared capacity at outdoor temperature	Tdaajanh		Back up heating capacity at outdoor tempera	tura Tdaaiga	h	unit
heating / Average $(-10^{\circ}C)$	Pdc	6.60 kW	heating / Average (-10°C)	elbu	0	kW
heating / Warmer (2°C)	Pdc	8.30 kW	heating / Warmer (2°C)	elbu	0	kW
heating / Colder (-22°C)	Pdc	- kW	heating / Colder (-22°C)	elbu	-	kW
······································			······································			
Declared capacity for cooling, at indoor temperature 27(19)°C and Declared energy efficiency ratio, at indoor temperature 27(19)°C and						
outdoor temperature Tj			outdoor temperature Tj			-
Tj=35°C	Pdc	7.10 kW	Tj=35°C	EERd	3.46	-
Tj=30°C	Pdc	5.23 kW	Tj=30°C	EERd	5.35	-
Tj=25°C	Pdc	3.36 kW	Tj=25°C	EERd	9.20	-
Tj=20°C	Pdc	3.20 kW	Tj=20°C	EERd	13.00	-
Declared capacity for heating / Average season, at indoor Declared coefficient of performance / Average season, at indoor						
temperature 20°C and outdoor temperatur			temperature 20°C and outdoor temperature	- ·	indoor	
Tj=-7°C	Pdh	5.84 kW	$T_j = -7^{\circ}C$	COPd	2.75	7-
Tj=2°C	Pdh	3.55 kW	Tj=2℃	COPd	4.50	1-
Tj=7℃	Pdh	<b>2.28</b> kW	Tj=7°C	COPd	5.90	-
Tj=12°C	Pdh	2.65 kW	Tj=12°C	COPd	7.30	-
Tj=bivalent temperature	Pdh	6.60 kW	Tj=bivalent temperature	COPd	2.20	-
Tj=operating limit	Pdh	6.46 kW	Tj=operating limit	COPd	2.15	-
Destant in factor (Wesser						
Declared capacity for heating / Warmer se temperature 20°C and outdoor temperatur			Declared coefficient of performance / Warme temperature 20°C and outdoor temperature 7		Indoor	
Tj=2°C	Pdh	8.30 kW	Tj=2°C	COPd	2.62	٦_
Tj=7°C	Pdh	5.34 kW	Ti=7°C	COPd	5.15	1_
Tj=12°C	Pdh	2.65 kW	Ti=12°C	COPd	7.30	1_
Tj=bivalent temperature	Pdh	8.30 kW	Tj=bivalent temperature	COPd	2.62	1-
Tj=operating limit	Pdh	6.46 kW	Tj=operating limit	COPd	2.15	1-
Declared capacity for heating / Colder sea			Declared coefficient of performance / Colder		ndoor	
temperature 20°C and outdoor temperatur	•	<u>_</u>	temperature 20°C and outdoor temperature			-
Tj=−7°C	Pdh	- kW	Tj=-7°C	COPd	-	-
Tj=2°C	Pdh	- kW - kW	Tj=2°C	COPd	-	-
Tj=7°C Tj=12°C	Pdh Pdh	- kW - kW	Tj=7℃   Tj=12℃	COPd COPd		1_
Tj=bivalent temperature	Pdh	- kW	Tj=bivalent temperature	COPd		-
Tj=operating limit	Pdh	- kW	Tj=operating limit	COPd	-	1_
Tj=−15°C	Pdh	- kW	Tj=−15°C	COPd	-	-
Bivalent temperature			Operating limit temperature			-
heating / Average	Tbiv	<u>-10</u> °C	heating / Average	Tol	-15	°C
heating / Warmer	Tbiv	2 °C	heating / Warmer	Tol	-15	°C
heating / Colder	Tbiv	- °C	heating / Colder	Tol	-	°C
Cycling interval capacity			Cycling interval efficiency			
for cooling	Pcycc	- kW	for cooling	EERcyc	-	7_
for heating	Pcych	- kW	for heating	COPcyc	-	1-
		1 1				
Degradation coefficient			Degradation coefficient			
cooling	Cdc	0.25 -	heating	Cdh	0.25	-
Electric power input in power modes other			Annual electricity consumption	-		<b>7</b>
off mode	Poff	<u>5</u> W		Qce	346	kWh∕a
standby mode thermostat-off mode	Psb Pto	<u>5</u> W 16W	heating / Average heating / Warmer	Qhe Qhe	2055 2039	kWh∕a kWh∕a
crankcase heater mode	Pck	0 W	heating / warmer heating / colder	Qhe	- 2039	kWh/a
	TOK			Gille	1	
Capacity control(indicate one of three opti	ions)		Other items			
			Sound power level(indoor)	Lwa	58	dB(A)
			Sound power level(outdoor)	Lwa	65	dB(A)
fixed	No		Global warming potential	GWP	1975	kgCO2eq.
staged	No		Rated air flow(indoor)	-	1230	m3/h
variable	Yes		Rated air flow(outdoor)	-	3300	m3/h
Contact details for obtaining Name and address of the manufacturer or of its authorised representative.						
Contact details for obtaining more information Mitsub		address of the manufact stries Air-Conditioning Eu	•			
	•	Stockley Park, Uxbridge,				
	Kingdom					